

## UNITED STATES ENVIRONMENTAL PROTECTION AGENCY

Region II Office

SUBJECT: Finalization of Draft Permit for  
National Gypsum Co., 2SD OXW 2 000570

DATE: April 22, 1974

FROM: Leon D. Lazarus  
Environmental Chemist  
Industrial Water Facilities Branch

TO: Facilities Technology Division

37120

Robert Matthews, Attorney  
Water Enforcement Branch  
Enforcement & Regional Counsel Division

Russell Norris of the National Oceanic and Atmospheric Administration supplied the only comment. Mr. Norris agreed with the limits in the permit.

The following changes are suggested in order to be consistent with EPA's policy on cooling water:

Condition 9(c)

	<u>Maximum</u>
Chromium-total*	1 mg/liter
Zinc-Total*	1 mg/liter

\*If the permittee does not use a chromium or zinc corrosion inhibitor, the permittee does not have to sample for chromium or zinc.

Sampling Schedules III and IV

Chromium-total*	Quarterly	Quarterly	Composite
Zinc-total*	Quarterly	Quarterly	Composite

\*If the permittee does not use a zinc or chromium corrosion inhibitor, the permittee does not have to sample for chromium or zinc.

Approved by:

92/957  
Jeff Zelikson, P.E., Chief  
Toxic & Inorganic Wastes Section  
Industrial Water Facilities Br.

Ernest A. Regna  
Ernest A. Regna, Chief  
Industrial Water Facilities Br.  
Facilities Technology Division